	BioPharma Product Testing	Test Facility Eurofins Biolab S.r.l	Test Report No: S-2017-04060 SAM
			Revision: 0 Version: English Page: 1 of 3 Print date: 16-Jan-18

## TEST REPORT S-2017-04060 SAM

<b>TEST METHOD</b>			
ASTM F838-15a - Standard test method for determining microbial retention of membrane filters utilized for liquid filtration.			
<b>TEST SAMPLE</b>			
<b>IDENTIFICATION</b>		SMART SHOWER FILTER BACTERIA STOP	
<b>SAMPLE TYPOLOGY</b>		Detergent / household product, i.e. filter cartridges for shower filter	
<b>STERILIZATION</b>		No sterile product	
<b>BATCH N.</b>	Not provided	<b>CODE</b>	Not provided
<b>MANUFACTURING DATE</b>	Not provided	<b>EXPIRY DATE</b>	Not provided
<b>MANUFACTURER</b>		LABORNUM LTD	
<b>MATERIALS</b>		Not provided	
<b>SAMPLE ID</b>	ACE-2017-00117478	<b>RECEIVING N.</b>	EUITVI-95802
		<b>RECEIVING DATE</b>	28-Aug-17
	ACE-2017-00133682	<b>RECEIVING N.</b>	EUITVI-96846
		<b>RECEIVING DATE</b>	24-Oct-17
<b>EQUIPMENT</b>			
Ordinary microbiology laboratory equipment and in particular:			
Filtration system SARTORIUS			
Cellulose Nitrate (CN) Membrane Filter (0.2µm pore sizes) SARTORIUS			
Swinnex, Ø47mm (filter holder) MILLIPORE			
Peristaltic pump MASTERFLEX (Model: 77200-52) GHIARONI			
<b>ANALYSIS STARTING DATE</b>		27-Nov-17	<b>ANALYSIS ENDING DATE</b>
			12-Dec-17
<b>EXPERIMENTAL CONDITIONS</b>			
<b>NOTE</b>	The filtration validation was performed in triplicate using the standard specifications, i.e. $3 \times 10^{-3}$ LPM/cm <sup>2</sup> .		
<b>TEST TEMPERATURE</b>	Room temperature		
<b>SPORE CONCENTRATION</b>	$\geq 10^7$ cfu/cm <sup>2</sup> of the filter surface (the container with the microbial suspension was connected to the test device)		
<b>FILTRATION VOLUME</b>	2000 ml		
<b>FILTRATION TIME</b>	About 17 seconds		
<b>TEST SURFACE</b>	2400 cm <sup>2</sup> (EFA, effective filtration area)		
<b>FLOW RATE</b>	Air flow 3 mL/min		

### Eurofins Biolab S.r.l.

Società con Socio unico sottoposta a direzione e coordinamento della società Eurofins Pharma Services Italia Holding parte di Eurofins Scientific Group  
 InfoFarma@eurofins.com  
 www.eurofins.it www.biolab.it

Via Bruno Buozzi, 2  
 20090 Vimodrone (MI)  
 Tel. + 39-022507151  
 Fax + 39-0225071599

certificata@pec.biolab.it

C.SOC. € 100.000 i.v.  
 P. IVA 00762140960  
 C.F. 03765750157  
 REA MI 966696  
 D-U-N-S 429117112  
 CIT005

DILUENT/RECOVERY FLUID	<i>Page's Saline</i> Sodium Chloride 0.12 g Magnesium Sulphate 0.004 g Calcium Chloride 0.004 g Disodium hydrogen phosphate 0.142 g Potassium dihydrogenphosphate 0.136 g Purified water q.s. to 1000 ml
TEST STRAINS	<i>Legionella pneumophila</i> ATCC33152
INCUBATION PERIOD	48 hour and 7 days (for the test) 72 hour and 7 days (for the control)
INCUBATION TEMPERATURE	37°C ±1°C
<b>TEST METHOD (SUMMARY DESCRIPTION)</b>	
PREPARATION OF THE BACTERIAL SUSPENSION	<p>The bacterial strain was kept freeze dried, according to internal Eurofins Biolab procedure SOP/GMB/009.</p> <p>The bacterial strain was transplanted on BCYE agar once and incubated at 37°C ± 1°C for 7 days. Within two hours from the beginning of the test, the final culture was suspended in Page's Saline using glass beads, and the suspension was centrifuged at 2000 g for 15 minutes. Pellet was suspended in Page's Saline and the bacterial suspension was diluted to a required concentration by means a spectrophotometer.</p>
COUNT OF THE VALIDATION BACTERIAL SUSPENSION	<p>The obtained bacterial strain was then diluted with peptone water to prepare the suspension containing not less than 10<sup>7</sup> CFU/cm<sup>2</sup> of the filter surface. The number of cfu/ml was determined by spreaded method by seeding of 1 ml for each dilutions (executed twice) on BCYE agar.</p>
FLOW RATE VALIDATION	<p>The test solution was filtered through the test sample and the filtered liquid was collected into a volumetric flask of 2000 ml; a stopwatch was started at the begin of the filtration and it was stopped at the finish of the 2000 ml filtration, in order to define the required flow rate.</p> <p>The flow value used in the retention test corresponds to the value obtained by adjusting the power of the peristaltic pump in order to ensure at least the theoretical flow. The flow rate values were expressed as l/min.</p>
TEST EXECUTION	<p>For each replica, the test sample was connected with a Swinnex filter holder containing a CN Membrane Filter (0.45µm pore sizes, previously sterilized), that was used for the control of the final microbial recovery;</p> <p>The volume (2 L) of the test solution, inoculated with a microbial suspension containing not less than 10<sup>7</sup> CFU/cm<sup>2</sup> of the filter surface, was filtered according to the required flow rate by means a container connected at the input with the air flow and at the output to the test filter; a filtration in continuous was so performed through the test sample SMART SHOWER FILTER BACTERIA STOP previously prepared and using a peristaltic pump that was connected with a Swinnex filter holder containing a CN Membrane Filter (0.45µm pore sizes) that was used for the control of the final microbial recovery. At the end of the filtration, the second Cellulose Nitrate Membrane Filter (SARTORIUS) was transferred onto agar plate and after incubation, the number of the residual microbial contamination was determined.</p> <p>The entire procedure was performed on triplicate for each test strain.</p>


**Eurofins Biolab S.r.l.**


 Società con Socio unico sottoposta  
 a direzione e coordinamento della società  
 Eurofins Pharma Services Italia Holding  
 parte di Eurofins Scientific Group  
 InfoFarma@eurofins.com  
 www.eurofins.it www.biolab.it

 Via Bruno Buozzi, 2  
 20090 Vimodrone (MI)  
 Tel. + 39-022507151  
 Fax + 39-0225071599

certificata@pec.biolab.it

 C.SOC. € 100.000 i.v.  
 P. IVA 00762140960  
 C.F. 03765750157  
 REA MI 966696  
 D-U-N-S 429117112  
 CIT005

 BioPharma Product Testing	Test Facility Eurofins Biolab S.r.l	Test Report No: S-2017-04060 SAM
		Revision: 0 Version: English Page: 3 of 3 Print date: 16-Jan-18

CONTROL	<p>In order to verify the initial contamination of the test item and to verify the entire assay system, the same procedure above described for the test was used on the test sample filtering through this, the equivalent volume of the liquid provided for the test but without microbial inoculum.</p> <p>The control was run immediately prior to the bacterial challenge test, and the control and challenge analysis filters were incubated simultaneously.</p> <p>The entire procedure was performed on triplicate for each test strain.</p>		
CALCULATION AND EXPRESSION OF THE RESULTS	<p>The counting was performed using the number of colonies counted on each plate. The plates showing a number of colonies included in a range of 30-300 and 20-200 for the filtration method were used to perform the result calculation.</p> <p><i>Microbial Retention</i>  <math>R = No - Na</math>          Where:          R = Microbial Reduction (filter performance)          No = initial inoculum          Na = residual microbial counting on the second filter</p> <p>When no colonies are found on the analysis filter, the R is expressed as greater than the total number of the initial inoculum.</p>		
ASSAY VALIDITY CRITERIA	<p><i>N (inoculum)</i>: must be not less than <math>10^7</math> cfu/cm<sup>2</sup> of the test filter surface area  <i>Control</i>: no growth/plate</p> <p>The test item is considered effective in the bacterial retention when <math>R \geq 7</math> Log.</p>		
RESULTS	<b>Log reductions (R) on the test filter</b>		
	<i>Legionella pneumophila</i>	REPLICA 1	>9.16
		REPLICA 2	>9.16
		REPLICA 3	>9.16
See Attachment N.1			
CONCLUSIONS	<p>On the basis of the results obtained, the test sample results effective in the bacterial retention against <i>Legionella pneumophila</i> ATCC33152 since the number of Log reductions on the test filter are &gt;7 Log as per ASTM F838-15a and in compliance with the Sponsor requirements.</p>		
ATTACHMENT	N. 1: RAW DATA ELABORATION (1 page)		
STUDY DIRECTOR (LAURA BRAMBILLA)			ISSUED ON: 16-Jan-18


This document may not be reproduced in part unless expressly approved in writing by Eurofins Biolab.  
 The test results relate only to the items tested. Sampling, except specific indication on test report, is always intended to be made by the manufacturer. Characterization of the test sample is under Sponsor responsibility.

### Eurofins Biolab S.r.l.

Società con Socio unico sottoposta a direzione e coordinamento della società Eurofins Pharma Services Italia Holding parte di Eurofins Scientific Group  
 InfoFarma@eurofins.com  
 www.eurofins.it www.biolab.it

Via Bruno Buozzi, 2  
 20090 Vimodrone (MI)  
 Tel. + 39-022507151  
 Fax + 39-0225071599  
 certificata@pec.biolab.it

C.SOC. € 100.000 i.v.  
 P. IVA 00762140960  
 C.F. 03765750157  
 REA MI 966696  
 D-U-N-S 429117112  
 CIT005

 <b>eurofins</b>	Standard test method for determining bacterial retention of membrane filters utilized for liquid filtration	EDR: 1-P-QM-TEM-9047099
	Norma (Standard): ASTM F838 - 15a	Pagina (Page) 1 / 1

Data inizio (Started on): 27/11/17

ID. studio (ID. Study): S-2017-04060 SAM

ID. campione (ID. sample): ACE-2017-00117478  
ACE-2017-00133682

Test strains	Dil	N		Microscopic count		Effective Filtration Area (cm <sup>2</sup> )
				cells n1	22	2400
Legionella pneumophila ATCC33152		ufc / plate	ufc / plate	cells n2	26	Inoculum volume (ml)
	-6	>330	>330	cells n3	31	1
	-7	>330	>330	Counted cells	79	Inoculum level/ cm <sup>2</sup>
	-8	294	288	Average/square	1.6	1.2E+07
	Mean values (ufc/ml)	2.9E+10		Dilution factor	100000	VALIDO (VALID)
	Vitality (%)	72.5		Total cells	4.0.E+10	Total Inoculum (2000 ml)
		NON VALIDO (NOT VALID)				2.9E+10

N: conteggio sospensione batterica (N: count of the bacterial suspension)

Test strains		Retention of membrane filters		
		Test challenge		
		REPLICA 1	REPLICA 2	REPLICA 3
Legionella pneumophila ATCC33152	ufc (contaminant)/plate	0	1	0
	ufc/plate	0	0	0
	Na	< 20	< 20	< 20
	R (Log)/filter	> 9.16	> 9.16	> 9.16
		Control		
		REPLICA 1	REPLICA 2	REPLICA 3
	ufc/plate	20	7	11

Na = microrganismi residui ufc/membrana (Na = residual microorganism cfu/membrane)

R = performance del filtro, riduzione della vitalità (R = filter performance, vitality reduction)

Sigla tecnico (Technician signature):



Data fine (Finished on): 04/12/17

Sigla Approvazione (Approval signature):



Data (Date): 12/12/17

Revision: 1	Local reference: Mod. PS/MIC/095.E
© This document is copyright of Eurofins Scientific Group	Approved document in ETQ