



EMC TEST REPORT
For

Xiamen Healthpal Electronic Co., Ltd.

Foot Massager

Test Model: FE-5311

Additional Model No.: Please Refer to Page 9

Prepared for : Xiamen Healthpal Electronic Co., Ltd.
Address : 3-4/F, NO.170, SIMING PARK, INDUSTRIAL
CONCENTRATION ZONE, TONGAN DISTRICT,
XIAMEN CITY, CHINA

Prepared by : Shenzhen LCS Compliance Testing Laboratory Ltd.
Address : Room 101, 201, Building A and Room 301, Building C,
Juji Industrial Park, Yabianxueziwei, Shajing Street,
Bao'an District, Shenzhen, Guangdong, China

Tel : (+86)755-82591330
Fax : (+86)755-82591332
Web : www.LCS-cert.com
Mail : webmaster@LCS-cert.com

Date of receipt of test sample : October 12, 2021
Number of tested samples : 1
Serial number : Prototype
Date of Test : October 12, 2021~ October 16, 2021
Date of Report : October 29, 2021





EMC TEST REPORT	
EN IEC 55014-1:2021	
Electromagnetic compatibility - Requirements for household appliances, electric tools and similar apparatus - Part 1: Emission	
EN IEC 55014-2:2021	
Electromagnetic compatibility - Requirements for household appliances, electric tools and similar apparatus - Part 2: Immunity - Product family standard	
Report Reference No.	LCS210907130AE
Date Of Issue	October 29, 2021
Testing Laboratory Name	Shenzhen LCS Compliance Testing Laboratory Ltd.
Address	Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China
Testing Location/ Procedure ..	Full application of Harmonised standards <input checked="" type="checkbox"/> Partial application of Harmonised standards <input type="checkbox"/> Other standard testing method <input type="checkbox"/>
Applicant's Name	Xiamen Healthpal Electronic Co., Ltd.
Address	3-4/F, NO.170, SIMING PARK, INDUSTRIAL CONCENTRATION ZONE, TONGAN DISTRICT, XIAMEN CITY, CHINA
Test Specification:	
Standard	EN IEC 55014-1:2021 EN IEC 61000-3-2:2019/A1:2021 EN 61000-3-3: 2013+A1: 2019 EN IEC 55014-2:2021
Test Report Form No.	LCSEMC-1.0
TRF Originator	Shenzhen LCS Compliance Testing Laboratory Ltd.
Master TRF	Dated 2011-03
SHENZHEN LCS COMPLIANCE TESTING LABORATORY LTD. All rights reserved.	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the SHENZHEN LCS COMPLIANCE TESTING LABORATORY LTD. is acknowledged as copyright owner and source of the material. SHENZHEN LCS COMPLIANCE TESTING LABORATORY LTD. takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
Test Item Description	Foot Massager
Trade Mark	N/A
Test Model	FE-5311
Ratings	Please Refer to Page 8
Result	Positive

Compiled by:

Coco Song

Coco Song/ File administrators

Supervised by:

Baron Wen

Baron Wen/Technique principal

Approved by:



Gavin Liang/ Manager



EMC -- TEST REPORT

Test Report No. : LCS210907130AE	<u>October 29, 2021</u> Date of issue
---	--

Test Model..... : FE-5311 EUT..... : Foot Massager	
Applicant..... : Xiamen Healthpal Electronic Co., Ltd. Address..... : 3-4/F, NO.170, SIMING PARK, INDUSTRIAL CONCENTRATION ZONE, TONGAN DISTRICT, XIAMEN CITY, CHINA Telephone..... : / Fax..... : /	
Manufacturer..... : Xiamen Healthpal Electronic Co., Ltd. Address..... : 3-4/F, NO.170, SIMING PARK, INDUSTRIAL CONCENTRATION ZONE, TONGAN DISTRICT, XIAMEN CITY, CHINA Telephone..... : / Fax..... : /	
Factory 1..... : Xiamen Healthpal Electronic Co., Ltd. Address..... : 3-4/F, NO.170, SIMING PARK, INDUSTRIAL CONCENTRATION ZONE, TONGAN DISTRICT, XIAMEN CITY, CHINA Telephone..... : / Fax..... : /	

Test Result according to the standards on page 8:	Positive
---	-----------------

The test report merely corresponds to the test sample.
It is not permitted to copy extracts of these test result without the written permission of the test laboratory.



Revision History

Revision	Issue Date	Revisions	Revised By
000	October 29, 2021	Initial Issue	Gavin Liang



TABLE OF CONTENT

Test Report Description	Page
1. SUMMARY OF STANDARDS AND RESULTS	6
1.1. Description of Standards and Results	6
1.2. Description of Performance Criteria	7
2. GENERAL INFORMATION	8
2.1. Description of Device (EUT)	8
2.2. Test Facility	8
2.3. Statement of the Measurement Uncertainty	8
2.4. Measurement Uncertainty	9
3. MEASURING DEVICES AND TEST EQUIPMENT	10
4. TEST RESULTS	11
4.1. Power Line Conducted Emission Measurement	11
4.2. Disturbance Power Measurement	13
4.3. Harmonic Current Emission Measurement	15
4.4. Voltage Fluctuation And Flicker Measurement	16
4.5. Electrostatic Discharge Immunity Test	17
4.6. Electrical Fast Transient/Burst Immunity Test	19
4.7. Surge Immunity Test	21
4.8. Injected Currents Susceptibility Test	23
4.9. Voltage Dips And Interruptions Test	25
ANNEX A.....	27
ANNEX B.....	31
ANNEX C.....	41



1. SUMMARY OF STANDARDS AND RESULTS

1.1. Description of Standards and Results

The EUT have been tested according to the applicable standards as referenced below.

EMISSION (EN IEC 55014-1:2021)			
Description of Test Item	Standard	Limits	Results
Conducted disturbance at mains terminals	EN IEC 55014-1:2021	-----	PASS
Disturbance Power	EN IEC 55014-1:2021	-----	PASS
Radiated disturbance	EN IEC 55014-1:2021	-----	N/A
Harmonic current emissions	EN IEC 61000-3-2:2019/A1:2021	Class A	N/A
Voltage fluctuations & flicker	EN 61000-3-3: 2013+A1: 2019	-----	PASS
IMMUNITY (EN IEC 55014-2:2021)			
Description of Test Item	Basic Standard	Performance Criteria	Results
Electrostatic discharge (ESD)	EN 61000-4-2: 2009	B	PASS
Radio-frequency, Continuous radiated disturbance	EN 61000-4-3: 2006+A2: 2010	A	N/A
Electrical fast transient (EFT)	EN 61000-4-4: 2012	B	PASS
Surge (Input a.c. power ports)	EN 61000-4-5: 2014+A1: 2017	B	PASS
Radio-frequency, Continuous conducted disturbance	EN 61000-4-6: 2014	A	PASS
Power frequency magnetic field	EN 61000-4-8: 2010	A	N/A
Voltage dips, 60% reduction	EN 61000-4-11: 2004+A1: 2017	C	PASS
Voltage dips, 30% reduction		C	PASS
Voltage interruptions		C	PASS
N/A is an abbreviation for Not Applicable.			

Test mode:		
Mode 1	Working	Record
Mode2	Charging	Pre-scan



1.2. Description of Performance Criteria

General Performance Criteria

Examples of functions defined by the manufacturer to be evaluated during testing include, but are not limited to, the following:

- essential operational modes and states;
- tests of all peripheral access (hard disks, floppy disks, printers, keyboard, mouse, etc.);
- quality of software execution;
- quality of data display and transmission;
- quality of speech transmission.

1.2.1. Performance criterion A

The equipment shall continue to operate as intended without operator intervention. No degradation of performance or loss of function is allowed below a performance level specified by the manufacture when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, then either of these may be deliver from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.

1.2.2. Performance criterion B

After the test, the equipment shall continue to operate as intended without operator intervention. No degradation of performance or loss of function is allowed, after the application of the phenomena below a performance level specified by the manufacture, when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance.

During the test, degradation of performance is allowed. However, no change of operation state or stored data is allowed to persist after the test.

If the minimum performance level (or the permissible performance loss) is not specified by the manufacturer, then either of these may be deliver from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.

1.2.3. Performance criterion C

Loss of function is allowed, provided the function is self-recoverable, or can be restored by the operation of the controls by the user in accordance with the manufacture's instructions.

Functions, and/or information stored in non-volatile memory, or protected by a battery backup, shall not be loss.



2. GENERAL INFORMATION

2.1. Description of Device (EUT)

EUT	: Foot Massager
Trade Mark	: N/A
Test Model	: FE-5311
Model Lists	: FE-5305, FE-5307, FE-5308, FE-5309, FE-5310, FE-5318, FE-5319, FE-5500, FE-5501, FE-5501-1, FE-5320, FE-5321, OB-3012, FE-5301, FE-5302
Model Declaration	: PCB board, structure and internal of these model(s) are the same, So no additional models were tested
Power Supply	: Input:220-240V~, 50/60Hz
EUT Clock Frequency	: ≤ 15 MHz

2.2. Test Facility

EMC Lab.	: NVLAP Accreditation Code is 600167-0. FCC Designation Number is CN5024. CAB identifier is CN0071. CNAS Registration Number is L4595.
----------	---

2.3. Statement of the Measurement Uncertainty

The data and results referenced in this document are true and accurate. The reader is cautioned that there may be errors within the calibration limits of the equipment and facilities. The measurement uncertainty was calculated for all measurements listed in this test report acc. To CISPR 16 – 4 “Specification for radio disturbance and immunity measuring apparatus and methods – Part 4: Uncertainty in EMC Measurements” and is documented in the LCS quality system acc. To DIN EN ISO/IEC 17025. Furthermore, component and process variability of devices similar to that tested may result in additional deviation. The manufacturer has the sole responsibility of continued compliance of the device.

2.4.Measurement Uncertainty

Test	Parameters	Expanded uncertainty (U _{lab})	Expanded uncertainty (U _{cispr})
Conducted Emission	Level accuracy (9kHz to 150kHz)	± 2.63 dB	± 3.8 dB
	(150kHz to 30MHz)	± 2.35 dB	± 3.4 dB
Power Disturbance	Level accuracy (30MHz to 300MHz)	± 2.90dB	± 4.5 dB
Electromagnetic Radiated Emission (3-loop)	Level accuracy (9kHz to 30MHz)	± 3.60 dB	± 3.3 dB
Radiated Emission	Level accuracy (9kHz to 30MHz)	± 3.68 dB	N/A
Radiated Emission	Level accuracy (30MHz to 1000MHz)	± 3.48 dB	± 5.3 dB
Radiated Emission	Level accuracy (above 1000MHz)	± 3.90 dB	± 5.2 dB
Mains Harmonic	Voltage	± 0.510%	N/A
Voltage Fluctuations & Flicker	Voltage	± 0.510%	N/A

- (1) Where relevant, the following measurement uncertainty levels have been estimated for tests performed on the apparatus.
- (2) The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor of k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%.




3. MEASURING DEVICES AND TEST EQUIPMENT

3.1. Conducted Disturbance						
Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Due Date
1	EMI Test Software	EZ	EZ-EMC	/	N/A	N/A
2	EMI Test Receiver	R&S	ESR3	102312	2021-03-16	2022-03-15
3	Artificial Mains	R&S	ENV216	101119	2021-06-21	2022-06-20
4	10dB Attenuator	SCHWARZBEC K	MTS-IMP-136	261115-001-0032	2021-06-21	2022-06-20
5	Impedance Stabilization Network	TESEQ	ISN T800	45130	2020-12-02	2021-12-01
3.2. Disturbance Power						
Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Due Date
1	EMI Test Software	E3	E3-EMC	/	N/A	N/A
2	EMI Test Receiver	R&S	ESR3	102312	2021-03-16	2022-03-15
3	Power Absorbing Clamp	R&S	MDS21	4033	2021-07-21	2022-07-20
4	10dB Attenuator	SCHWARZBEC K	MTS-IMP-136	261115-001-0032	2021-06-21	2022-06-20
3.3. Voltage fluctuation and Flicker /Harmonic Current						
Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Due Date
1	Power Analyzer Test System	Voltech	PM6000	20000670053	2021-06-21	2022-06-20
3.4. Electrostatic Discharge						
Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Due Date
1	ESD Simulator	SCHLODER	SESD 230	604035	2021-07-20	2022-07-19
3.5. Electrical Fast Transient/Burst						
Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Due Date
1	Immunity Simulative Generator	EM TEST	UCS500 M4	0101-34	2021-06-21	2022-06-20
3.6. Surge						
Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Due Date
1	Immunity Simulative Generator	EM test	UCS500 M4	0101-34	2021-06-21	2022-06-20
3.7. Conducted Susceptibility						
Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Due Date
1	Simulator	FRANKONIA	CIT-10/75	A126A1195	2021-06-21	2022-06-20
2	CDN	FRANKONIA	CDN-M2+M3	A2210177	2021-06-21	2022-06-20
3	6dB Attenuator	FRANKONIA	DAM25W	1172040	2021-06-21	2022-06-20
3.8. Voltage Dips/ Voltage Short Interruptions						
Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Due Date
1	Voltage dips and up generator	3CTEST	VDG-1105G	EC0171014	2021-06-21	2022-06-20

4. TEST RESULTS

4.1. Power Line Conducted Emission Measurement

4.1.1. Block Diagram of Test Setup



4.1.2. Power Line Conducted Emission Limits

Frequency (MHz)	Limit (dB μ V)	
	Quasi-peak Level	Average Level
0.15 ~ 0.50	66.0 ~ 56.0 *	59.0 ~ 46.0 *
0.50 ~ 5.00	56.0	46.0
5.00 ~ 30.00	60.0	50.0

Remark: * means decreasing linearly with logarithm of frequency.

4.1.3. EUT Configuration on Test

The following equipments are installed on Conducted Emission Measurement to meet EN IEC 55014–1 requirements and operating in a manner which tends to maximize its emission characteristics in a normal application.

4.1.4. Operating Condition of EUT

4.1.4.1. Setup the EUT as shown on Section 4.1.1.

4.1.4.2. Turn on the power of all equipments.

4.1.4.3. Let the EUT work in measuring Mode 1 and measure it.



4.1.5. Test Procedure

The EUT is put on the plane 0.8m high above the ground by insulating support and connected to the AC mains through a Line Impedance Stability Network (L.I.S.N). This provided a 50ohm coupling impedance for the tested equipments. Both sides of AC line are investigated to find out the maximum conducted emission according to the EN IEC 55014-1 regulations during conducted emission measurement.

The bandwidth of the field strength meter is set at 9kHz.

The frequency range from 150kHz to 30MHz is investigated. The scanning waveform please refer to the next page.


4.1.6. Test Results

PASS.

Refer to attached Annex B.1

4.2. Disturbance Power Measurement

4.2.1. Block Diagram of Test Setup



4.2.2. Test Standard

EN IEC 55014-1:2021

4.2.3. Disturbance Power Limits

All emanations from devices or system including any network of conductors and apparatus connected there to, shall not exceed the level of field strengths specified below:

Frequency MHz	Limits dB(pW)	
	Quasi-peak Value	Average Value
30 ~ 300	45 Increasing Linearly with Frequency to 55	35 Increasing Linearly with Frequency to 45

1	Household and similar appliances		Tools					
	2	3	4	5	6	7	8	9
Frequency range			Rated motor power not exceeding 700 W		Rated motor power above 700 W and not exceeding 1000 W		Rated motor power above 1000 W	
(MHz)	dB (pW) Quasi-peak	dB (pW) Average	dB (pW) Quasi-peak	dB (pW) Average	dB (pW) Quasi-peak	dB (pW) Average	dB (pW) Quasi-peak	dB (pW) Average
Increasing linearly with the frequency from:								
200 to 300	0 to 10 dB	-	0 to 10 dB	-	0 to 10 dB	-	0 to 10 dB	-
NOTE 1 This table only applies if specified in 4.1.2.3.2.								
NOTE 2 The measured result at a particular frequency shall be less than the relevant limit minus the corresponding margin (at that frequency).								



4.2.4.EUT Configuration on Test

The EN IEC 55014-1 Regulations test method must be used to find the maximum emission during radiated emission measurement. The configuration of the EUT is the same as used in conducted emission measurement.

4.2.5.Operating Condition of EUT

Same as conducted emission measurement, which is listed in Section 4.1.1 except the test set up replaced as Section 4.2.1.

4.2.6.Test Procedure

The EUT is placed on the plane 0.8m high above the ground by insulating support and away from other metallic surface at least 0.4m. It is connected to the power mains through an extension cord of 6m min. The absorber clamp clamps the cord and moves from the far end to the EUT to measure the disturbing energy emitted from the cord.


The bandwidth of the field strength meter is set at 120kHz.
All the test results are listed in Section 4.2.7.

4.2.7.Test Results

PASS.
Refer to attached Annex B.2

4.3. Harmonic Current Emission Measurement

4.3.1. Block Diagram of Test Setup



4.3.2. Test Standard

EN IEC 61000-3-2:2019/A1:2021, Class A

4.3.3. Operation Condition of EUT

Same as Section 4.1.4 except the test setup replaced as Section 4.3.1.


4.3.4. Test Results

Pass.

Refer to attached Annex B.3

4.4. Voltage Fluctuation And Flicker Measurement

4.4.1. Block Diagram of Test Setup



4.4.2. Test Standard

EN 61000-3-3: 2013+A1: 2019

4.4.3. Operation Condition of EUT

4.4.3.1. Setup the EUT as shown Section 4.4.1.

4.4.3.2. Turn on the power of all equipments.

4.4.3.3. Let EUT work in test mode (On/Off) and measure it.


4.4.4. Test Results

PASS.

Refer to attached Annex B.4

4.5. Electrostatic Discharge Immunity Test

4.5.1. Block Diagram of Test Setup



4.5.2. Test Standard

EN IEC 55014-2:2021(EN 61000-4-2: 2009, Severity Level: 3 / Air Discharge: $\pm 8\text{KV}$; Level: 2 / Contact Discharge: $\pm 4\text{KV}$)

4.5.3. Severity Levels and Performance Criterion

4.5.3.1. Severity level

Level	Test Voltage Contact Discharge (KV)	Test Voltage Air Discharge (KV)
1.	± 2	± 2
2.	± 4	± 4
3.	± 6	± 8
4.	± 8	± 15
X	Special	Special

4.5.3.2. Performance criterion: **B**

4.5.4. EUT Configuration on Test

The configuration of EUT are listed in Section 4.5.1.

4.5.5. Operating Condition of EUT

Same as conducted emission measurement, which is listed in Section 4.1.4, except the test set up replaced by Section 4.5.1.



4.5.6. Test Procedure

4.6.6.1. Air Discharge

This test is done on a non-conductive surface. The round discharge tip of the discharge electrode shall be approached as fast as possible to touch the EUT. After each discharge, the discharge electrode shall be removed from the EUT. The generator is then re-triggered for a new single discharge and repeated 10 times for each pre-selected test point. This procedure shall be repeated until all the air discharge completed.

4.5.6.2. Contact Discharge

All the procedure shall be same as Section 4.5.6.1. except that the tip of the discharge electrode shall touch the EUT before the discharge switch is operated.

4.5.6.3. Indirect Discharge For Horizontal Coupling Plane

At least 10 single discharges (in the most sensitive polarity) shall be applied at the front edge of each HCP opposite the center point of each unit (if applicable) of the EUT and 0.1m from the front of the EUT. The long axis of the discharge electrode shall be in the plane of the HCP and perpendicular to its front edge during the discharge.

4.5.6.4. Indirect Discharge For Vertical Coupling Plane

At least 10 single discharges (in the most sensitive polarity) shall be applied to the center of one vertical edge of the coupling plane. The coupling plane, of dimensions 0.5m X 0.5m, is placed parallel to, and positioned at a distance of 0.1m from the EUT. Discharges shall be applied to the coupling plane, with this plane in sufficient different positions that the four faces of the EUT are completely illuminated.


4.5.7. Test Results

PASS.

Refer to attached Annex B.5

4.6. Electrical Fast Transient/Burst Immunity Test

4.6.1. Block Diagram of Test Setup



4.6.2. Test Standard

EN IEC 55014-2:2021 (EN 61000-4-4: 2012, Severity Level: Level 2: 1KV)

4.6.3. Severity Levels and Performance Criterion

4.7.3.1. Severity level

Open Circuit Output Test Voltage $\pm 10\%$		
Level	On Power Supply Lines	On I/O (Input/Output) Signal data and control lines
1.	0.50KV	0.25KV
2.	1.00KV	0.50KV
3.	2.00KV	1.00KV
4.	4.00KV	2.00KV
X	Special	Special

4.6.3.2. Performance criterion: **B**

4.6.4. EUT Configuration on Test

The configuration of EUT are listed in Section 4.6.1.

4.6.5. Operating Condition of EUT

4.6.5.1. Setup the EUT as shown in Section 4.6.1.

4.6.5.2. Turn on the power of all equipments.

4.6.5.3. Let the EUT work in test Mode 1 and measure it.



4.6.6. Test Procedure

The EUT is put on the table which is 0.8 meter high above the ground. This reference ground plane shall project beyond the EUT by at least 0.1m on all sides and the minimum distance between EUT and all other conductive structure, except the ground plane beneath the EUT, shall be more than 0.5m.

4.6.6.1. For input and output AC power ports:

The EUT is connected to the power mains by using a coupling device which couples the EFT interference signal to AC power lines. Both polarities of the test voltage should be applied during compliance test and the duration of the test is 2 mins.

4.6.6.2. For signal lines and control lines ports:

No I/O ports. It's unnecessary to test.

4.6.6.3. For DC output line ports:

No DC output ports. It's unnecessary to test.


4.6.7. Test Results

PASS.

Refer to attached Annex B.6

4.7. Surge Immunity Test

4.7.1. Block Diagram of Test Setup



4.7.2. Test Standard

EN IEC 55014-2:2021

(EN 61000-4-5: 2014+A1 : 2017, Severity Level: Level 2, Line to Line: 1.0KV; Level 3: Line to Ground: 2.0KV)

4.7.3. Severity Levels and Performance Criterion

4.8.3.1. Severity level

Severity Level	Open-Circuit Test Voltage (KV)
1	0.5
2	1.0
3	2.0
4	4.0
X	Special

4.7.3.2. Performance criterion: **B**

4.7.4. EUT Configuration on Test

The configuration of EUT are listed in Section 4.7.1.

4.7.5. Operating Condition of EUT

4.7.5.1. Setup the EUT as shown in Section 4.7.1.

4.7.5.2. Turn on the power of all equipments.

4.7.5.3. Let the EUT work in test Mode 1 and measure it.



4.7.6. Test Procedure

- 4.7.6.1. Set up the EUT and test generator as shown on Section 4.7.1.
- 4.7.6.2. For line to line coupling mode, provide a 1.0 KV 1.2/50us voltage surge (at open-circuit condition) and 8/20us current surge to EUT selected points.
- 4.7.6.3. At least 5 positive and 5 negative (polarity) tests with a maximum 1/min repetition rate are conducted during test
- 4.7.6.4. Different phase angles are done individually.
- 4.7.6.5. Record the EUT operating situation during compliance test and decide the EUT immunity criterion for above each test.


4.7.7. Test Results

PASS.

Refer to attached Annex B.7

4.8. Injected Currents Susceptibility Test

4.8.1. Block Diagram of Test Setup



4.8.2. Test Standard

EN IEC 55014-2:2021(EN 61000-4-6: 2014, Severity Level: 3V (rms), (0.15MHz ~ 230MHz))

4.8.3. Severity Levels and Performance Criterion

4.8.3.1. Severity level

Level	Field Strength (V)
1	1
2	3
3	10
X	Special

4.8.3.2. Performance criterion: **A**

4.8.4. EUT Configuration on Test

The configuration of EUT are listed in Section 4.8.1.

4.8.5. Operating Condition of EUT

4.8.5.1. Setup the EUT as shown in Section 4.8.1.

4.8.5.2. Turn on the power of all equipments.

4.8.5.3. Let the EUT work in test Mode 1 and measure it.



4.8.6. Test Procedure

4.8.6.1. Set up the EUT, CDN and test generators as shown on Section 4.8.1.

4.8.6.2. Let the EUT work in test mode and measure it.

4.8.6.3. The EUT are placed on an insulating support 0.1m high above a ground reference plane. CDN (coupling and decoupling device) is placed on the ground plane about 0.3m from EUT. Cables between CDN and EUT are as short as possible, and their height above the ground reference plane shall be between 30 and 50 mm (where possible).

4.8.6.4. The disturbance signal described below is injected to EUT through CDN.

4.8.6.5. The EUT operates within its operational mode(s) under intended climatic conditions after power on.

4.8.6.6. The frequency range is swept from 150kHz to 230MHz using 3V signal level, and with the disturbance signal 80% amplitude modulated with a 1kHz sine wave.

4.8.6.7. The rate of sweep shall not exceed 1.5×10^{-3} decades/s. Where the frequency is swept incrementally, the step size shall not exceed 1% of the start and thereafter 1% of the preceding frequency value.

4.8.6.8. Recording the EUT operating situation during compliance testing and decide the EUT immunity criterion.


4.8.7. Test Results

PASS.

Refer to attached Annex B.8

4.9. Voltage Dips And Interruptions Test

4.9.1. Block Diagram of Test Setup



4.9.2. Test Standard

EN IEC 55014-2:2021 (EN 61000-4-11: 2004+A1 : 2017)

4.9.3. Severity Levels and Performance Criterion

4.9.3.1. Severity level

Test Level (%U _T)	Voltage dip and short interruptions (%U _T)	Duration (in period)	
		0.5	0.6
0	100	10	12
40	60	25	60
70	30		

4.9.3.2. Performance criterion: **C&C**

4.9.4. EUT Configuration on Test

The configuration of EUT are listed in Section 4.9.1.

4.9.5. Operating Condition of EUT

4.9.5.1. Setup the EUT as shown in Section 4.9.1.

4.9.5.2. Turn on the power of all equipments.

4.9.5.3. Let the EUT work in test Mode 1 and measure it.



4.9.6. Test Procedure

4.9.6.1. Set up the EUT and test generator as shown on Section 4.9.1.

4.9.6.2. The interruptions is introduced at selected phase angles with specified duration.

4.9.6.3. Record any degradation of performance.

4.9.7. Test Results

PASS.

Refer to attached Annex B.9


ANNEX A

(Test photograph)

A.1.Photo of Power Line Conducted Measurement




A.2.Photo of Disturbance Power Test




A.3. Photo of Harmonic & Flicker Measurement




A.4. Photo of Electrostatic Discharge Test




A.5. Photo of Electrical Fast Transient/Burst Test & Surge Immunity Test



A.6. Photo of Injected Currents Susceptibility Test



A.7.Photo of Voltage Dips and Interruptions Test




ANNEX B

(Emission and Immunity test results)

B.1 POWER LINE CONDUCTED EMISSION MEASUREMENT

Environmental Conditions:	22.5°C, 53.7% RH
Test Voltage:	AC 230V,50Hz
Test Model:	FE-5311
Test Mode:	Mode 1
Test Engineer:	Hubert
Pol:	Line

Detailed results are shown below




No.	Frequency (MHz)	Reading (dBuV)	Correct (dB)	Result (dBuV)	Limit (dBuV)	Margin (dB)	Remark
1	0.1548	36.87	19.76	56.63	65.74	-9.11	QP
2	0.1582	18.85	19.76	38.61	58.43	-19.82	AVG
3	0.3031	27.50	19.77	47.27	60.16	-12.89	QP
4	0.3031	9.23	19.77	29.00	51.40	-22.40	AVG
5	0.4516	18.53	19.78	38.31	56.85	-18.54	QP
6	0.4516	5.52	19.78	25.30	47.10	-21.80	AVG
7	4.5825	18.21	19.91	38.12	56.00	-17.88	QP
8	4.5825	3.61	19.91	23.52	46.00	-22.48	AVG
9	7.5571	17.60	20.01	37.61	60.00	-22.39	QP
10	7.5571	5.67	20.01	25.68	50.00	-24.32	AVG
11	11.6611	16.32	20.23	36.55	60.00	-23.45	QP
12	11.6611	6.37	20.23	26.60	50.00	-23.40	AVG



Environmental Conditions:	22.5°C, 53.7% RH
Test Voltage:	AC 230V,50Hz
Test Model:	FE-5311
Test Mode:	Mode 1
Test Engineer:	Hubert
Pol:	Neutral

Detailed results are shown below




No.	Frequency (MHz)	Reading (dBuV)	Correct (dB)	Result (dBuV)	Limit (dBuV)	Margin (dB)	Remark
1	0.1694	36.61	19.76	56.37	64.99	-8.62	QP
2	0.1726	17.09	19.76	36.85	57.48	-20.63	AVG
3	0.2581	26.05	19.75	45.80	61.49	-15.69	QP
4	0.2581	7.69	19.75	27.44	53.14	-25.70	AVG
5	0.4066	16.07	19.77	35.84	57.72	-21.88	QP
6	0.4066	0.91	19.77	20.68	48.23	-27.55	AVG
7	2.1390	-0.51	19.85	19.34	46.00	-26.66	AVG
8	2.1976	12.04	19.85	31.89	56.00	-24.11	QP
9	6.2836	18.03	19.96	37.99	60.00	-22.01	QP
10	6.2836	5.44	19.96	25.40	50.00	-24.60	AVG
11	10.9501	16.90	20.17	37.07	60.00	-22.93	QP
12	10.9501	5.07	20.17	25.24	50.00	-24.76	AVG



B.2 Disturbance Power Measurement

Environmental Conditions:	22.5°C, 53.7% RH
Test Voltage:	AC 230V,50Hz
Test Model:	FE-5311
Test Mode:	Mode 1
Test Engineer:	Hubert

Detailed results are shown below



No.	Frequency (MHz)	Reading (dBpW)	Correct (dB)	Result (dBpW)	Limit (dBpW)	Margin (dB)	Remark
1	40.0800	-4.38	10.00	5.62	35.37	-29.75	AVG
2	40.6800	11.09	10.00	21.09	45.40	-24.31	QP
3	101.5199	-3.82	11.09	7.27	37.65	-30.38	AVG
4	102.0600	12.05	11.12	23.17	47.67	-24.50	QP
5	135.7200	11.56	11.80	23.36	48.92	-25.56	QP
6	135.7200	-12.29	11.80	-0.49	38.92	-39.41	AVG
7	160.0200	15.85	11.90	27.75	49.82	-22.07	QP
8	160.0200	15.40	11.90	27.30	39.82	-12.52	AVG
9	199.9800	-6.82	11.60	4.78	41.30	-36.52	AVG
10	200.1000	8.84	11.59	20.43	51.30	-30.87	QP
11	247.5000	-12.92	10.44	-2.48	43.06	-45.54	AVG
12	247.6200	17.35	10.44	27.79	53.06	-25.27	QP



B.3 Harmonic Current Emission Measurement

Pass

Because the power of EUT is less than 75W, according standard EN 61000-3-2, harmonic current unnecessary to test.



B.4 Voltage Fluctuation And Flicker Measurement

Test Voltage:	AC 230V,50Hz			
Test Model:	FE-5311			
Test Engineer:	Hubert			
Detailed results are shown below				
Overall Result: PASS	Notes: Measurement method - Voltage			
	Pst	dc (%)	dmax (%)	d(t) > 3.3%(ms)
Limit	1.000	3.300	4.000	500
Reading 1	0.089	0.009	0.145	0



B.5 Electrostatic Discharge Immunity Test

Electrostatic Discharge Test Results						
Standard	<input type="checkbox"/> IEC 61000-4-2 <input checked="" type="checkbox"/> EN 61000-4-2					
Applicant	Xiamen Healthpal Electronic Co., Ltd.					
EUT	Foot Massager	Temperature		23.2°C		
M/N	FE-5311	Humidity		53.5%		
Criterion	B	Pressure		1021mbar		
Test Mode	Mode 1	Test Engineer		Hubert		
Test Voltage	AC 230V/50Hz					
Air Discharge						
Test Points	Test Levels			Results		
	± 2kV	± 4kV	± 8kV	Passed	Fail	Performance Criterion
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Top	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Bottom	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Contact Discharge						
Test Points	Test Levels		Results			
	± 2 kV	±4 kV	Passed	Fail	Performance Criterion	
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B	
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B	
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B	
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B	
Top	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B	
Bottom	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B	
Discharge To Horizontal Coupling Plane						
Side of EUT	Test Levels		Results			
	± 2 kV	± 4 kV	Passed	Fail	Performance Criterion	
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B	
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B	
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B	
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B	
Discharge To Vertical Coupling Plane						
Side of EUT	Test Levels		Results			
	± 2 kV	± 4 kV	Passed	Fail	Performance Criterion	
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B	
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B	
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B	
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B	

**B.6 Electrical Fast Transient/Burst Immunity Test****Electrical Fast Transient/Burst Test Results**

Standard	<input type="checkbox"/> IEC 61000-4-4 <input checked="" type="checkbox"/> EN 61000-4-4		
Applicant	Xiamen Healthpal Electronic Co., Ltd.		
EUT	Foot Massager	Temperature	24.5°C
M/N	FE-5311	Humidity	54.4%
Test Mode	Mode 1	Criterion	B
Test Engineer	Hubert	Test Voltage	AC 230V/50Hz

Line	Test Voltage	Result (+)	Result (-)
L	1KV	PASS	PASS
N	1KV	PASS	PASS
PE			
L-N	1KV	PASS	PASS
L-PE			
N-PE			
L-N-PE			
Signal Line			
I/O Cable			

Note:



B.7 Surge Immunity Test

Surge Immunity Test Result			
Standard	<input type="checkbox"/> IEC 61000-4-5 <input checked="" type="checkbox"/> EN 61000-4-5		
Applicant	Xiamen Healthpal Electronic Co., Ltd.		
EUT	Foot Massager	Temperature	22.6°C
M/N	FE-5311	Humidity	53.4%
Test Mode	Mode 1	Criterion	B
Test Engineer	Hubert	Test Voltage	AC 230V/50Hz

Location	Polarity	Phase Angle	Number of Pulse	Pulse Voltage (KV)	Result
L-N	+	90°	5	1.0	PASS
	-	270°	5	1.0	PASS
L-PE					
N-PE					
Signal Line					
Note					



B.8 Injected Currents Susceptibility Test

Injected Currents Susceptibility Test Results			
Standard	<input type="checkbox"/> IEC 61000-4-6 <input checked="" type="checkbox"/> EN 61000-4-6		
Applicant	Xiamen Healthpal Electronic Co., Ltd.		
EUT	Foot Massager	Temperature	23.7°C
M/N	FE-5311	Humidity	52.3%
Test Mode	Mode 1	Criterion	A
Test Engineer	Hubert	Test Voltage	AC 230V/50Hz

Frequency Range (MHz)	Injected Position	Strength (Unmodulated)	Criterion	Result
0.15 ~ 230	AC Mains	3V	A	PASS

Note:



B.9 Voltage Dips And Interruptions Test

Voltage Dips And Interruptions Test Results			
Standard	<input type="checkbox"/> IEC 61000-4-11 <input checked="" type="checkbox"/> EN 61000-4-11		
Applicant	Xiamen Healthpal Electronic Co., Ltd.		
EUT	Foot Massager	Temperature	22.5°C
M/N	FE-5311	Humidity	53.8%
Test Mode	Mode 1	Criterion	C&C
Test Engineer	Hubert	Test Voltage	AC 230V/50Hz

Test Level % U _T	Voltage Dips & Short Interruptions % U _T	Duration (in periods)		Criterion	Result
		50Hz	60Hz		
40	60	10P	12P	C	PASS
70	30	25P	60P	C	PASS
0	100	0.5P	0.6P	C	PASS

Note:

ANNEX C

(External and internal photos of the EUT)



Fig. 1



Fig. 2



Fig. 3



Fig. 4




Fig. 5



Fig. 6




Fig. 7




Fig. 8




Fig. 9



Fig. 10




Fig. 11




Fig. 12



Fig. 13




Fig. 14



Fig. 15




Fig. 16

-----THE END OF TEST REPORT-----